Government of Bihar

Public Health Engineering Department

DISTRICT :- SAMASTIPUR			DIVISION :- SAMASTIPUR								MONTH: MAY 2026					
S.N.	BLOCK	PANCHAYAT	LOCATION OF SOURCE	PARAMETERS												REMARKS
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COLI		
1	SAMASTIPUR	MOHANPUR	TECHNO MISSION SCHOOL MOHANPUR, SAMASTIPUR	7.1	1	100	65	38	18	17	12	45	0.1	-Ve		
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250mg/l	30 mg/l	200 mg/l	1.0mg/l			-
Permissible Limit* in Absence of Alternate source as per BIS 10500/2012				NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	1000 mg/l	100 mg/l	600 mg/l	NR			-

Chemist /Lab Assistant
P.H. Division Samastipur

30.09.26
Principal
Techno Mission School
Samastipur, Bihar

Poonam Kumari
Manager
Techno Mission School
Samastipur, Bihar